

Water samples tested in Department of Microbiology IGMC, Shimla										
Lab Sr. no.	Date	Received through Email/Phone No.	Daily Sr No.	Source	Site	Na thiosulphate	PCC	DCC	Reported on	Result
1612	13-Oct	Samples received from Corporate Health Officer, Municipal Corporation Shimla, Shimla (H.P)	1	Main Tank Bharari	-	Added	0	-	15-Oct	Excellent
1613			2	Main Tank Kelestan	-	Added	0	-		Excellent
1614			3	Public Tap Police line Bharari	-	Added	0	-		Excellent
1615			4	Public Tap Bharari Bazaar	-	Added	0	-		Excellent
1616			5	Main Tank Kasumpti	-	Added	0	-		Excellent
1617			6	Sanjauli Reservoir Gumma Inlet	-	Added	0	-		Excellent
1618			7	Sanjauli Reservoir Giri Inlet	-	Added	0	-		Excellent
1619			8	Sanjauli Reservoir Outlet	-	Added	0	-		Excellent
1620	14-Oct	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla (H.P)	1	Main Tank Knowledge Wood Nigam Vihar	-	Added	0	-	16-Oct	Excellent
1621			2	Public Tap Khalini Chowk	-	Added	0	-		Excellent
1622			3	Public Tap Hanuman Mandir Road Lower Khalini	-	Added	0	-		Excellent
1623			4	Main Tank Kasumpati	-	Added	0	-		Excellent
1624			5	Reservoir Sanjauli Outlet	-	Added	0	-		Excellent
1625			6	Guma Inlet Reservoir Sanjauli	-	Added	25	-		Unsatisfactory
1626			7	Giri Inlet Reservoir Sanjauli	-	Added	0	-		Excellent