

Water samples tested in Department of Microbiology IGMC, Shimla										
Lab Sr. no.	Date	Received through Email/Phone No.	Daily Sr No.	Source	Site	Na thiosulphate	PCC	DCC	Reported on	Result
1964	4-Dec	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla (H.P)	1	Sukrala Near Type IV Tank		Added			6-Dec	Excellent
1965			2	Basant Vihar Storage Tank Ram Ground		Added	0	-		Excellent
1966			3	Mehuli Public tap		Added	0	-		Excellent
1967			4	Sanjauli reservoir outlet		Added	0	-		Excellent
1968			5	Sanjauli Inlet Guma		Added	0	-		Excellent
1969			6	Sanjauli inlet Giri		Added	0	-		Excellent
1970			7	Kasumpti Reservoir		Added	0	-		Excellent
1971	5-Dec	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla (H.P)	1	Sanjauli reservoir outlet		Added				Excellent
1972			2	Sanjauli Inlet Guma		Added				Excellent
1973			3	Sanjauli inlet Giri		Added				Excellent
1974			4	Engine Ghar Tank		Added				Excellent
1975			5	bangla colony public tap		Added				Excellent
1976			6	bangala colony tank		Added				Excellent
1977			7	Kasumpti Reservoir		Added				Excellent
1978	6-Dec	Samples received from Corporation Health Officer, Municipal Corporation Shimla Shimla (H.P)	1	Snow Down pump house		Added	1	-	8-Dec	Satisfactory but not Excellent
1979			2	Sanjauli reservoir outlet		Added	0	-		Excellent
1980			3	Sanjauli Inlet Guma		Added	180+			Unsatisfactory
1981			4	Sanjauli inlet Giri		Added	0	-		Excellent
1982			5	Central Store Maliana Tap		Added	0	-		Excellent
1983			6	Kasumpti Reservoir		Added	0	-		Excellent