

MUNICIPAL CORPORATION SHIMLA  
(Health Dept.)

Daily water testing Report - in dt-09-02-2016.

<u>Sl. No</u>	<u>Dated</u>	<u>Name and Place of Sample</u>	<u>Coliform per 100ml</u>	<u>Residual Chlorine</u>
1.	9-2-16	Lakkar Bazar	NIL	2.0 ppm
2.	"	Snow Down Pump House	NIL	2.0 ppm
3.	"	Sanjauli chowk	NIL	2.0 ppm +
4.	"	Mains field	NIL	2.0 ppm
5.	"	Kasumpti Reservoir	NIL	2.0 ppm +
6.	"	Shaghi	NIL	0.6 ppm
7.	"	Nasha	NIL	0.8 ppm
8.	"	Chauramanidan	NIL	1.0 ppm
9.	"	Ridge	NIL	2.0 ppm +
10.	"	Lab. Tap	NIL	2.0 ppm +

No: mes/CHD/2016-223

Dated 12/2/16

(Janki Srivastava)

1. Humble Mayer, M.C. Shimla for information please.
2. Humble Dy. Mayer, M.C. Shimla for information please.
3. Commissioner, M.C. Shimla for information please.
4. C. M. O Distt. Shimla for information please.
5. D. H. S. Govt. of H.P. Shimla for information please.
6. Engineer in Chief I.B.H. Shimla for information please.
7. M.E, M.C. Shimla for information and note please.
8. I/c IT cell.
9. Notice Board.
10. Office Copy.

Corporation Health Officer  
Municipal Corporation Shimla.