

MUNICIPAL CORPORATION SRINAGAR
(Health Deptt.)

Daily water testing Report on D^r 06-02-2016.

Sr.no	Dated	Name and Place of Sample	Coliform Per 100ml	Residual Chlorine
1.	6.2.16	Ridge	NIL	2.0 ppm
2.	"	Bhagrat Niwas	NIL	2.0 ppm
3.	"	Shimla club	NIL	0.4 ppm
4.	"	Mains field	NIL	0.8 ppm
5.	"	Kashmir Reservoir	NIL	2.0 ppm
6.	"	Sanjauli Chowk	NIL	2.0 ppm
7.	"	Snowdown Pump House	NIL	1.0 ppm
8.	"	Lakecar Bazaar	NIL	2.0 ppm
9.	"	Lab. Taps	NIL	2.0 ppm

No: mes [CMO] 2016-205

Dated 9/2/16

Yours
S. Tech.

1. Humble mayor, M.C. Shimla for information Please
2. Humble Dy. mayor, M.C. Shimla for information Please
3. Commissioner, M.C. Shimla for information Please
4. C.M.O Distt. Shimla for information Please.
5. D.H.S. Govt. of H.B. Shimla for information Please
6. Engineer in Chief I.B.H. Shimla for information Please
7. M.C. Shimla for information and res Please.
8. I/C IT cell
9. Notice Board
10. office copy.

Corporation Health officer,
Municipal Corporation Srinagar.