


**SHIMLA MUNICIPAL CORPORATION**  
(HEALTH DEPARTMENT)

NO.MCS/CHO/2016-428

DATED: 10/3/16


REPORT OF WATER SAMPLES COLLECTED ON 05-03-2016.

S.No.	Location of samples collected	Coliform		Residual Chlorine	
		Result	Range	Result	Range
1.	Sangrudi Gnlal-Cuma	M/L	Should not be deductable	2.00PPm	0.2 to 2.00PPM
2.	Sangrudi Gnlal-Civn	M/L		1.00PPm	--
3.	Court Complex	M/L	--	1.00PPm	--
4.	Advance Study	M/L	--	1.00PPm	--
5.	Summer Hill Railway Station	M/L	--	1.00PPm	--
6.	Chaura Maidan	M/L	--	1.00PPm	--
7.	Ridge	M/L	--	2.00PPm	--
8.	Lab. Tap	M/L	--	2.00PPm	--

  
 Signature of Sr. Lab Technician

Copy to :-

1. The Hon'ble Mayor, MC, Shimla.
2. The Hon'ble Dy. Mayor, MC, Shimla.
3. The Commissioner, MC, Shimla.
4. The Director, Health Services, HP, Shimla.
5. Engineer-in-Chief, IPH, HP, Shimla.
6. The Chief Medical Officer, Distt. Shimla, Shimla.
7. The Municipal Engineer, WS&SD, MC, Shimla
8. IT Cell, MC, Shimla for uploading on official website of Municipal Corporation, Shimla.
9. Office copy.

  
 Corporation Health Officer,  
 M.C.Shimla.