

MUNICIPAL CORPORATION SHIMLA
(Health Dept.)

Daily water testing Report under date 27-02-2016.


Sr. no	Dated	Name and place of Sample	Coliform Per 100 ml	Residual Chlorine.
1.	27.2.16	L.S. M.C. Shimla	NIL	2.00ppm
2.	"	Sanjauli Chowk	NIL	3.00ppm
3.	"	Sanjauli Dingro chowk	NIL	2.00ppm
4.	"	Sanjauli Gulet Gini	NIL	0.50ppm
5.	"	Under Nagar	NIL	0.50ppm
6.	"	Kasumpti Reservoir	NIL	2.00ppm
7.	"	Kasumpti Chowk	NIL	2.00ppm
8.	"	Ridge	NIL	2.00ppm
9.	"	Lub. Taps	NIL	2.00ppm

No: mes/CHD/16-336

Dated - 3/3/16

Janki
S. Tech.

1. Humble mayor, m.c. Shimla for information please
2. Humble Dy. mayor, m.c. Shimla for information please
3. Commissioner, m.c. Shimla for information please
4. C. M.O Dist. Shimla for information please
5. D.H.S. Court of H.P. Shimla for information please
6. Engineer in chief I.P.H. Shimla for information please
7. M.E, m.c. Shimla for information and n/a please
8. I/T IC cells
9. Notice Board
10. Office copy.


 Corporation Health Officer,
 Municipal Corporation Shimla.