

Water samples tested in Department of Microbiology IGMC, Shimla										
Lab Sr. no.	Date	Received through Email/Phone No.	Daily Sr No.	Source	Site	Na thiosul phate	PCC	Final report (72Hrs)	Report ed on	Result
154	23-Jan	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	water tank phase III near police chowki BCS New Shimla		added	0	-	25-Jan	Excellent
155			2	water tank phase III block 6,7 New Shimla	-	added	0	-	25-Jan	Excellent
156			3	public tap lower Pantha ghati	-	added	0	-	25-Jan	Excellent
157			4	water tank underground IAS colony sergean	-	added	0	-	25-Jan	Excellent
158			5	water tank overhead IAS colony sergean	-	added	0	-	25-Jan	Excellent
159			6	water tank Kasumpti outlet	-	added	0	-	25-Jan	Excellent
160			7	Sanjauli reserivior outlet	-	added	0	-	25-Jan	Excellent
161	24-Jan	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	Public tap lakkar bazar chowk	-	added	0	-	26-Jan	Excellent
162			2	public tap plice chowki lakkar baxar	-	added	0	-	26-Jan	Excellent
163			3	IGMC road pump house lakkar bazar	-	added	0	-	26-Jan	Excellent
164			4	IGMC public tap	-	added	0	-	26-Jan	Excellent
165			5	Sanjauli reservoir outlet	-	added	0	-	26-Jan	Excellent

166	25-Jan	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	public tap chota shimla bazar	-	added	0	-	27-Jan	in process
167			2	water tank kasumpti outlet	-	added	0	-	27-Jan	in process
168			3	water man's field (1) lt side chota shimla	-	added	0	-	27-Jan	in process
169			4	water tank man's filed (2) rt side chota shimla	-	added	0	-	27-Jan	in process
170			5	water sunpal Govner house kicten	-	added	35		27-Jan	nsatisfactor
171			6	water tank scitery govner house	-	added	0	-	27-Jan	in process
172			7	sanjuli outlet rejerwere	-	added	0	-	27-Jan	in process