

Water samples tested in Department of Microbiology IGMC, Shimla

Lab Sr. no.	Date	Received through Email/Phone No.	Daily Sr No.	Source	Na thiosulphate	PCC	Final report (72Hrs)	Reported on	Result
2657	28-Sep	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	ADVANCE STUDY TANK(JUNGLE)	added	MPN= 1	Negative for Esch.coli.	30-Sep	satisfactory
2658			2	SUMMER HILL CHOWK	added	MPN=1	Negative for Esch.coli.	30-Sep	satisfactory
2659			3	P.TAP, NR VICHEY GUPTA GENERAL STORE SUMMER HILL	added	MPN=2	Negative for Esch.coli.	30-Sep	satisfactory
2660			4	SUMMER HILL BAZAR TANK	added	MPN=0	-	30-Sep	Excellent
2661			5	P.TAP, LOWER SUMMER HILL	added	MPN=2	Negative for Esch.coli.	30-Sep	satisfactory
2662			6	KASUMPATI RESERVOIR	added	MPN=3	Negative for Esch.coli.	30-Sep	satisfactory
2663			7	SANJAULI RESERVOIR	added	MPN=0	-	30-Sep	Excellent
2664			8	WATER ATM RIDGE	added	MPN=18	Negative for Esch.coli.	30-Sep	Unsatisfactory
2665	28-Sep	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	Ridge tank shimla	added	MPN=0	-	30-Sep	excellent
2666			2	mainsfield tank	added	MPN=0	-	30-Sep	excellent

2667			3	pub. Tap S.D. school ganj bazar	added	MPN=1	_	30-Sep	
2668			4	dhalli tank	added	MPN=0	_	30-Sep	excellent
2669			5	tavi tank	added	MPN=0	_	30-Sep	excellent
2670			6	pub.tap near negi shop sector 3	added	MPN=0	_	30-Sep	excellent
2671			7	jakhu tank	added	MPN=0	_	30-Sep	excellent
2672			8	vikasnagar tank	added	MPN=0	_	30-Sep	excellent
2673			9	pub.tap near mangla bhawan sector 4	added	MPN=0	_	30-Sep	excellent
2674			10	pub.tap chotta shimla near police gumti	added	MPN=2	_	30-Sep	
2675			11	pub.tap chotta shimla near lakhshmi narayan mandir	added	MPN=2	_	30-Sep	
2676			12	bawari devnagar(tibtian colony)	nil	MPN=0	_	30-Sep	excellent
2677	29-Sep	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	Girls hostel Pump house from main supply MC	added	MPN=40	_	1-Oct	unsatisfactory
2678			2	Boys hostel pump house, from main supply MC	added	MPN=180+	_	1-Oct	unsatisfactory
2679			3	sanjauli tank inlet from gumma	added	MPN=8	_	1-Oct	in process
2680			4	sanjauli tank inlet giri	added	MPN=180	_	1-Oct	unsatisfactory
2681			5	sanjauli reserrior	added	MPN=180	_	1-Oct	unsatisfactory
2682			6	kasumpti reserrior	added	MPN=3	_	1-Oct	in process
2683			7	p.tap hari mandir gate chakkar	added	MPN=90	_	1-Oct	unsatisfactory
2684			8	chakkar tank	added	MPN=11	_	1-Oct	in process