

Water samples tested in Department of Microbiology IGMC, Shimla										
Lab Sr. no.	Date	Received through Email/Phone No.	Daily Sr No.	Source	Site	Na thiosulphate	PCC	Final report (72Hrs)	Reported on	Result
716	21-Apr	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	Sanjauli reservoir outlet	-	added	0	-	23-Apr	Excellent
717			2	Engine ghar tank	-	added	0	-	23-Apr	Excellent
718			3	Public tap Mehta niwas engine ghar	-	added	0	-	23-Apr	Excellent
719			4	Bangala colony tank	-	added	0	-	23-Apr	Excellent
720			5	Public tap Bangala colony	-	added	13			unsatisfactory
721			6	Kasumpti reservoir outlet	-	added	0	-	23-Apr	Excellent
722	22-Apr	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	p.tap near jain niwas tuti kandi	-	added	0	-	24-Apr	Excellent
723			2	p. tap tuti kandi bypass	-	added	0	-	24-Apr	Excellent
724			3	103 tunnel tank	-	added	0	-	24-Apr	Excellent
725			4	Tuti Kandi Tank	-	added	0	-	24-Apr	Excellent
726			5	kasumpti reservoir outlet	-	added	0	-	24-Apr	Excellent
727			6	sanjauli reservoir outlet	-	added	0	-	24-Apr	Excellent