

Water samples tested in Department of Microbiology IGMC, Shimla

Lab Sr. no.	Date	Received through Email/Phone No.	Daily Sr No.	Source	Site	Na thiosulphate	PCC	Final report (72Hrs)	Reported on	Result
860	14-May	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	Mains field outlet No. I	-	added	0	-	16-May	Excellent
861			2	Mains field outlet No. II	-	added	0	-	16-May	Excellent
862			3	Knollswood tank	-	added	0	-	16-May	Excellent
863			4	Public tap Khalini chowk	-	added	0	-	16-May	Excellent
864			5	Public tap Khalini Bypass	-	added	0	-	16-May	Excellent
865			6	kasumpti reservior outlet	-	added	0	-	16-May	Excellent
866			7	sanjauli reservior outlet	-	added	0	-	16-May	Excellent
867	15-May		1	Public tap near CTO	-	added	0	-	17-May	Excellent
868			2	IIAS Steel Tank	-	added	0	-	17-May	Excellent
869			3	Boileauganj Tank	-	added	0	-	17-May	Excellent
870			4	Public tap Pent Land Boileauganj	-	added	0	-	17-May	Excellent
871			5	Public tap near Boileauganj Police station	-	added	0	-	17-May	Excellent
872			6	kasumpti reservior outlet	-	added	0	-	17-May	Excellent
873			7	sanjauli reservior outlet	-	added	0	-	17-May	Excellent
874	16-May		1	kasumpti reservior outlet	-	added	0	-	18-May	Excellent
875			2	vikas nagar c-41 tank	-	added	0	-	18-May	Excellent
876			3	sanjauli reservior outlet	-	added	0	-	18-May	Excellent
877			4	sanjauli inlet gumma	-	added	0	-	18-May	Excellent
878			5	kalyani tank	-	added	0	-	18-May	Excellent
879			6	Retreat kichen	-	added	0	-	18-May	Excellent
880	17-May		1	Kasumpti Reservior outlet	-	added	0	-	19-May	Excellent
881			2	Sakrala near Type IV tank	-	added	0	-	19-May	Excellent
882			3	BasantVihar Storage tank at Rani ground	-	added	0	-	19-May	Excellent
883			4	Sanjauli reservior outlet	-	added	0	-	19-May	Excellent
884			5	Kalyani tank outlet	-	added	0	-	19-May	Excellent
885			6	Retreat kitchen	-	added	0	-	19-May	Excellent
886			7	Lambi Dhar tank outlet	-	added	180+	Esch.coli	19-May	unsatisfactory
887	18-May		1	Kasumpti Reservior outlet	-	added	0	-	20-May	Excellent

888			2	Sanjauli reservoir outlet	-	added	0	-	20-May	Excellent
889			3	North Oak Tank (OH)	-	added	0	-	20-May	Excellent
890			4	North Oak tank (UH)	-	added	0	-	20-May	Excellent
891			5	Kalyani Tank	-	added	0	-	20-May	Excellent
892			6	Retreat kitchen	-	added	0	-	20-May	Excellent
893			7	Lambidhar Tank	-	added	0	-	20-May	Excellent
894	19-May		1	Tube Well No 4 Ashwani Khad	-	added	180+	Esch.coli	21-May	unsatisfactory
895			2	Tube Well No 3 Ashwani Khad	-	added	100	Esch.coli	21-May	unsatisfactory
896			3	Tube Well No 1 Ashwani Khad	-	added	180+	Esch.coli	21-May	unsatisfactory
897			4	Kasumpati Reservoir	-	added	0	-	21-May	Excellent
898			5	Kasumpati Reservoir Outlet	-	added	0	-	21-May	Excellent
899			6	Sanjauli Reservoir Outlet	-	added	35	Esch.coli	21-May	unsatisfactory
900			7	Kalyani Tank Outlet	-	added	0	-	21-May	Excellent
901			8	Retreat Kitchen	-	added	0	-	21-May	Excellent
902	20-May		1	Kalyani tank outlet	-	added	0	-	22-May	Excellent
903			2	Retreat kitchen	-	added	0	-	22-May	Excellent
904			3	Sanjauli reservoir outlet	-	added	0	-	22-May	Excellent