

**Water samples tested in Department of Microbiology IGMC, Shimla**

Lab Sr. no.	Date	Received through Email/Phone No.	Daily Sr No.	Source	Site	Na thiosulphate	PCC	Final report (72Hrs)	Reported on	Result
1184	5-Jul	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	Bharari tank treated water	-	added	0	-	7-Jul	Excellent
1185			2	keleston tank treated water	-	added	5	Klebsiella spp.	8-Jul	suspicious
1186			3	sanjauli reservoir treated water	-	added	0	-	7-Jul	Excellent
1187			4	Tubewell No.2 Ashwani khad (u.v.) treated water	-	NIL	0	-	7-Jul	Excellent
1189			6	kasumpatti reservoir treated water	-	added	0	-	7-Jul	Excellent
1190	6-Jul	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	Public tap Railway station Shimla treated water	-	added	0	-	8-Jul	Excellent
1191			2	103 Tunnel Tank Treated Water	-	added	0	-	8-Jul	Excellent
1192			3	Tuti Kandi Tank Treated Water	-	added	0	-	8-Jul	Excellent
1194			5	Tube well No. 2 (U.V.) treated water	-	nil	0	-	8-Jul	Excellent
1195			6	kasumpatti reservoir treated water	-	added	0	-	8-Jul	Excellent
1196			7	sanjauli reservoir treated water	-	added	0	-	8-Jul	Excellent
1197	7-Jul	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	sanjauli reservoir treated water	-	added	0	-	9-Jul	Excellent
1198			2	Mashobra tank treated water	-	added	0	-	9-Jul	Excellent
1199			3	Public tap near Kapoor dhaba Mashobra treated water	-	added	0	-	9-Jul	Excellent
1200			4	Public tap Radha Krishan Mandir Mashobra treated water	-	added	0	-	9-Jul	Excellent
1201			5	Public tap near U.C.O. Bank Dhalli Bazar	-	added	0	-	9-Jul	Excellent
1203			7	Tube well No. 2 Ashwani khad (U.V.) treated water	-	nil	MPN=180+	Citrobacter freundii (180+/100 ml)	9-Jul	unsatisfactory
1204			8	kasumpatti reservoir treated water	-	added	0	-	9-Jul	Excellent

1205	8-Jul	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	advance study Tank treated water	-	added	0	-	10-Jul	Excellent
1206			2	Public tap Summer Hill Bazar treated water	-	added	0	-	10-Jul	Excellent
1207			3	summer hill bazar tank treated water	-	added	0	-	10-Jul	Excellent
1208			4	Public tap Lower Summer hill bazar treated water	-	added	0	-	10-Jul	Excellent
1209			5	kasumpatti reservoir treated water	-	added	0	-	10-Jul	Excellent
1211			7	Tube well No. 2 Ashwani khad (U.V.) treated water	-	NIL	0	-	10-Jul	Excellent
1212			8	sanjauli reservoir treated water	-	added	8	-	10-Jul	Excellent
1213	9-Jul	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	Water Tank tawri Totu	-	added	0	-	11-Jul	Excellent
1214			2	Public tap Vad building , new Totu	-	added	0	-	11-Jul	Excellent
1215			3	Public tap near Gupta PCO totu bazaar	-	added	0	-	11-Jul	Excellent
1216			4	water tank Yadghar totu	-	added	0	-	11-Jul	Excellent
1218			6	Tubewell 2 (U.V) Plant treated water Ashwani khad	-	nil	0	-	11-Jul	Excellent
1219			7	Water tank, kasumpti outlet	-	added	MPN=5	-	11-Jul	in process
1220			8	Sanjauli Reservoir Outlet	-	added	MPN=6	-	11-Jul	in process