

Water samples tested in Department of Microbiology IGMC, Shimla

Lab Sr. no.	Date	Received through Email/Phone No.	Daily Sr No.	Source	Site	Na thiosulphate	PCC	Final report (72Hrs)	Reported on	Result
1190	6-Jul	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	Public tap Railway station Shimla treated water	-	added	0	-	8-Jul	Excellent
1191			2	103 Tunnel Tank Treated Water	-	added	0	-	8-Jul	Excellent
1192			3	Tuti Kandi Tank Treated Water	-	added	0	-	8-Jul	Excellent
1193			4	Tube well No.2.(U.V) untreated water	-	nil	180+	citrobacter koseri	8-Jul	unsatisfactory
1194			5	Tube well No. 2 (U.V.) treated water	-	nil	0	-	8-Jul	Excellent
1195			6	kasumpatti reservoir treated water	-	added	0	-	8-Jul	Excellent
1196			7	sanjauli reservoir treated water	-	added	0	-	8-Jul	Excellent
1197	7-Jul	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	sanjauli reservoir treated water	-	added	0	-	9-Jul	Excellent
1198			2	Mashobra tank treated water	-	added	0	-	9-Jul	Excellent
1199			3	Public tap near Kapoor dhaba Mashobra treated water	-	added	0	-	9-Jul	Excellent
1200			4	Public tap Radha Krishan Mandir Mashobra treated water	-	added	0	-	9-Jul	Excellent
1201			5	Public tap near U.C.O. Bank Dhalli Bazar	-	added	0	-	9-Jul	Excellent
1202			6	Tube well No.2 Ashwani khad.(U.V) untreated water	-	nil	MPN=13		9-Jul	unsatisfactory
1203			7	Tube well No. 2 Ashwani khad (U.V.) treated water	-	nil	MPN=180+		9-Jul	unsatisfactory
1204			8	kasumpatti reservoir treated water	-	added	0	-	9-Jul	Excellent