

**Water samples tested in Department of Microbiology IGMC, Shimla**

Lab Sr. no.	Date	Received through Email/Phone No.	Daily Sr No.	Source	Site	Na thiosulphate	PCC	Final report (72Hrs)	Reported on	Result
1633	2-Aug	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	Public tap, Fire bench , Jakhoo	-	added	MPN=180+	E.coli (5/100ml)	4-Aug	unsatisfactory
1634			2	Public tap, Dhaulpur house, jakhoo	-	added	MPN=4	Klebsiella oxytoca	4-Aug	suspicious (unfit for drinking)
1635			3	Public tap, Baba Balak Nath Mandir, Jakhoo	-	added	0		4-Aug	excellent
1636			4	Jakhoo Tank Below Mandir (old) UG	-	added	0		4-Aug	excellent
1637			5	Tubewell no.2 (UV) Ashwani khad ( un treated	-	nil	MPN=180+	E.coli (5/100ml)	4-Aug	unsatisfactory
1638			6	Tubewell no.2 (UV) Ashwani khad (treated)	-	nil	0		4-Aug	excellent
1639			7	Kasumpti Reservoir	-	added	0		4-Aug	excellent
1640			8	Sanjauli Reservoir	-	added	0		4-Aug	excellent
1641	2-Aug	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	ridge tank shimla		added			4-Aug	excellent
1642			2	mains field tank		added			4-Aug	excellent
1643			3	caloston tank		added			4-Aug	excellent
1644			4	dhali tank		added			4-Aug	excellent
1645			5	chakkar tank		added			4-Aug	excellent
1646			6	phase -3 tank		added			4-Aug	excellent
1647			7	Jakhu tank		added			4-Aug	excellent
1648			8	sargeen tank		added			4-Aug	excellent
1649			9	bawari		nil	MPN=180+		4-Aug	unsatisfactory
1650			10	mipa		nil			4-Aug	excellent
1651			11	house hold roshan lal dhali		nil			4-Aug	excellent
1652			12	inder nagar dhali chander vohar		nil			4-Aug	excellent