Water samples tested in Department of Microbiology IGMC,Shimla										
Lab Sr. no.	Date	Received through Email/Phone No.	Daily Sr No.	Source	Site	Na thiosulphate	PCC	Final report (72Hrs)	Reported on	Result
1693	5-Aug	Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P)	1	Sanjauli tank inlet from gumma		added	0		7-Aug	excellent
1694			2	Sanjauli tank inlet from giri		added	0		7-Aug	excellent
1695			3	Sanjauli reservoir		added	0		7-Aug	excellent
1696			4	Engine ghar tank		added	MPN=1		7-Aug	Satisfactory
1697			5	Bangla colony tank Sanjauli		added	0		7-Aug	excellent
1698			6	Kasumpti reservoir		added	0		7-Aug	excellent
1699			7	Tube well no 2 (uv) Ashwani khad (untreated)		nil	MPN=180+	E.coli (5/100ml)	7-Aug	unsatisfactory
1700			8	Tube well no 2 (uv) Ashwani khad (treated)		nil	0		7-Aug	excellent