

| Water samples tested in Department of Microbiology IGMC, Shimla | | | | | | | | | | |
|---|-------|---|--------------|---|------|-----------------|----------|----------------------|-------------|----------------|
| Lab Sr. no. | Date | Received through Email/Phone No. | Daily Sr No. | Source | Site | Na thiosulphate | PCC | Final report (72Hrs) | Reported on | Result |
| 1701 | 6-Aug | Samples received from Corporation Health Officer, Municipal Corporation Shimla, Shimla(H.P) | 1 | P. Tap Police Post Lakkar Bazar | - | added | MPN=180+ | | | unsatisfactory |
| 1702 | | | 2 | Snowdon pump house | - | added | | | 8-Aug | excellent |
| 1703 | | | 3 | P.Tap FIVE BENCH Jakhoo | - | added | | | 8-Aug | excellent |
| 1704 | | | 4 | P.Tap Dhaulpur House Jakhoo | - | added | | | 8-Aug | excellent |
| 1705 | | | 5 | Kasumpti Reservoir | - | added | | | 8-Aug | excellent |
| 1706 | | | 6 | Tube well no.2 (UV) Ashwani Khad Untreated | - | nil | MPN-180+ | | | unsatisfactory |
| 1707 | | | 7 | Tube well no.2 (UV) Ashwani Khad treated | - | nil | | | 8-Aug | excellent |
| 1708 | | | 8 | Sanjauli reservoir | - | added | | | 8-Aug | excellent |
| 1709 | 6-Jul | Samples Received under Hepatitis Project Community Medicine IGMC Shimla | 1 | Ridge tank shimla | - | added | | | 8-Aug | excellent |
| 1710 | | | 2 | mains field tank | - | added | | | 8-Aug | excellent |
| 1711 | | | 3 | dhali tank | - | added | | | 8-Aug | excellent |
| 1712 | | | 4 | caloston tank | - | added | | | 8-Aug | excellent |
| 1713 | | | 5 | chakkar tank | - | added | | | 8-Aug | excellent |
| 1714 | | | 6 | phase -3 tank | - | added | | | 8-Aug | excellent |
| 1715 | | | 7 | Jakhu tank | - | added | | | 8-Aug | excellent |
| 1716 | | | 8 | sargeen tank | - | added | | | 8-Aug | excellent |
| 1717 | | | 9 | shiv bowari sammar hill | - | nil | MPN=180+ | | 8-Aug | unsatisfactory |
| 1718 | | | 10 | public tap water near hollylodge | - | nil | MPN=1 | | 8-Aug | |
| 1719 | | | 11 | public tap water | - | nil | MPN=1 | | 8-Aug | |
| | | | 12 | hand pump near lakkar bazar , public toilet | - | nil | MPN=50 | | 8-Aug | unsatisfactory |