

Water samples tested in Department of Microbiology IGMC, Shimla

Lab Sr. no.	Date	Received through Email/Phone	Daily Sr No.	Source	Site	Na thiosulph ate	PCC	Final report (72Hrs)	Reported on	Result
2052	26-Aug	Samples received from Corporation Health Officer, Municipal Corporation Shimla	1	Phase 3 Tank Nr. Mahila Police Station	-	added	0		28-Aug	excellent
2053			2	TaraMata Mandir Tank	-	added	MPN=50		28-Aug	unsatisfactory
2054			3	MC OFFICE TAP , Sec- 1 New shimla	-	added	0		28-Aug	excellent
2055			4	p.tap negi market new shimla sec 3	-	added	0		28-Aug	excellent
2056			5	new shimla sec 3tank (new)	-	added	0		28-Aug	excellent
2057			6	Kasumpati reservoir	-	added	0		28-Aug	excellent
2058			7	Sanjauli Tank inlet from Giri	-	added	0		28-Aug	excellent
2059			8	sanjauli Reservoir	-	added	0		28-Aug	excellent