

Lab Sr. no.	Date	Received through Email/Phone No	Daily Sr No.	Source	Sodium Thiosulphate	MPN	Final report (72Hrs)	FINAL REPORTING DATE	Result
4937	1/10/2019	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam Ltd	1	Kasumpati reservoir	added	MPN = 150	thermotolerant E.coli not detected	4/10/2019	UNSATISFACTORY
4938			2	Knolls wood tank(repeat)	added	MPN =1	thermotolerant E.coli not detected	4/10/2019	SATISFACTORY
4939			3	Public tap near Khalini chowk	added	MPN =1	thermotolerant E.coli not detected	4/10/2019	ADV : REPEAT SAMPLE
4940			4	public tap near lower Bypass Khalini	added	MPN =1	thermotolerant E.coli not detected	4/10/2019	ADV : REPEAT SAMPLE
4941			5	Public tap near Panchiatha	added	MPN =2	thermotolerant E.coli not detected	4/10/2019	ADV : REPEAT SAMPLE
4942			6	public tap near Kalimata mandir,Bhagvati nagar	added	MPN =2	thermotolerant E.coli not detected	4/10/2019	ADV : REPEAT SAMPLE
4943			7	supply near Sood bhawan, Bhagwatinagar	added	MPN =2	thermotolerant E.coli not detected	4/10/2019	ADV : REPEAT SAMPLE
4944			8	Sanjauli reservoir	added	MPN =7	thermotolerant E.coli not detected	4/10/2019	SUSPICIOUS
4945	1/10/2019	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	Ridge tank	added	MPN=0		3/10/2019	EXCELLENT
4946			2	Mainsfield tank	added	MPN=0		3/10/2019	EXCELLENT
4947			3	Kelaston tank	added	MPN=1		3/10/2019	
4948			4	Dhalli tank	added	MPN=0		3/10/2019	EXCELLENT
4949			5	Pub-tap yadgar	added	MPN=0		3/10/2019	EXCELLENT
4950			6	Knollswood tank	added	MPN=0		3/10/2019	EXCELLENT
4951			7	Jakhoo tank ropeway	added	MPN=0		3/10/2019	EXCELLENT
4952			8	Pub-tap brock host-2 chhota shimla	added	MPN=0		3/10/2019	EXCELLENT
4953			9	Pub-tap Police gumti Chotta Shimla	added	MPN=1		3/10/2019	
4954			10	Pub-tap apna medical store chotta Shimla	added	MPN=6		3/10/2019	
4955			11	Pub-tap servent quarter chotta shimla	added	MPN=0		3/10/2019	EXCELLENT
4956			12	Pub-tap MC office chotta shimla	added	MPN=0		3/10/2019	EXCELLENT
4957	2-Oct-19	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam Ltd	1	Kasumpti Reservoir	added	MPN=0	thermotolerant E.coli not detected	5/10/2019	EXCELLENT

4958			2	P.Tap near Dhaulpur House, Jakhoo	added	MPN=0	thermotolerant E.coli not detected	5/10/2019	EXCELLENT
4959			3	Jakhu temple near Hanuman temple	added	MPN=0	thermotolerant E.coli not detected	5/10/2019	EXCELLENT
4960			4	Jakhu tank near ropeway	added	MPN=0	thermotolerant E.coli not detected	5/10/2019	EXCELLENT
4961			5	Sanjauli reservoir	added	MPN=0	thermotolerant E.coli not detected	5/10/2019	EXCELLENT
4962			6	P.Tap near Police colony , Bharari (Repeat)	added	MPN=0	thermotolerant E.coli not detected	5/10/2019	EXCELLENT
4963			7	P.Tap near Laxmi Niwas, Annadale (Repeat)	added	MPN=0	thermotolerant E.coli not detected	5/10/2019	EXCELLENT
4964			8	Tara hall tank (Repeat)	added	MPN=0	thermotolerant E.coli not detected	5/10/2019	EXCELLENT