

Lab Sr. no.	Date	Received through Email/Phone No	Daily Sr No.	Source	Sodium Thiosulphate	MPN	Final report (72Hrs)	FINAL REPORTING DATE	Result
3365	05-07-19	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam	1	DHINGU MANDIR TANK	added	MPN=10	07-07-19		unsatisfactory
3366			2	P.TAP NEAR GOEL APARTMENT DHINGU	added	MPN=0	07-07-19	-	excellent
3367			3	KASUMPATI RESERVOIR	added	MPN=1	08-07-19	thermotolerant E.coli not detected	satisfactory
3368			4	P.TAP NEAR LAXMI NARAYAN TEMPLE SANJAULI	added	MPN=1	08-07-19	thermotolerant E.coli not detected	satisfactory
3369			5	P.TAP NEAR OLD POLICE THANA SANJAULI	added	MPN=13	08-07-19	thermotolerant E.coli not detected	unsatisfactory
3370			6	SANJAULI RESERVOIR	added	MPN=1	08-07-19	thermotolerant E.coli not detected	satisfactory
3371			7	NORTH OAK UG TANK	added	MPN=1	08-07-19	thermotolerant E.coli not detected	satisfactory
3372			8	NORTH OAK OH TANK	added	MPN=1	08-07-19	thermotolerant E.coli not detected	satisfactory
3373	05-07-19	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	Ridge tank	added	MPN=4			
3374			2	mains field tank	added	MPN=4			
3375			3	Kalaston Tank	added	MPN=1			
3376			4	Dhalli tank	added	MPN=40			unsatisfactory
3377			5	Pub-tap fullu bhawan dhanda	added	MPN=180			unsatisfactory
3378			6	Phase-3 tank	added	MPN=90			unsatisfactory
3379			7	Jakhu tank ropeway	added	MPN=11			unsatisfactory
3380			8	Pub-tap chintpurni chowk Khalini	added	MPN=5			

3381			9	Pub-tap sood bhawan bhagwati nagar	added	MPN=180+			unsatisfactory
3382			10	Pub-tap guleria house bhagwati nagar	added	MPN=20			unsatisfactory
3383			11	Pub-tap kalimata mandir khalani	added	MPN=90			unsatisfactory
3384			12	Pub-tap panchiyeta	added	MPN=20			unsatisfactory
3385	06-07-19	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam	1	KASUMPATI RESERVOIR	added	MPN=1			in process
3386			2	P.TAP MC OFFICE NEW SHIMLA	added	MPN=0	08-Jul-19	-	excellent
3387			3	SECT-1 TANK	added	MPN=0	08-Jul-19	-	excellent
3388			4	TARA MATA MANDIR TANK	added	MPN=3			in process
3389			5	PHASE-3 TANK NO.1 NEAR POLICE THANA	added	MPN=0	08-Jul-19	-	excellent
3390			6	PHASE-3 TANK NO.2 NEAR BLOCK 6 & 7	added	MPN=0	08-Jul-19	-	excellent
3391			7	P.TAP NEAR SERVANT QUARTER KNOLLSWOOD	added	MPN=0	08-Jul-19	-	excellent
3392			8	SANJAULI RESERVOIR	added	MPN=0	08-Jul-19	-	excellent
3393	06-07-19	Samples Received under Hepatitis Project Community Medicine IGMC	1	Ridge tank	added	MPN=0	08-Jul-19	-	excellent
3394			2	mains field tank	added	MPN=1			
3395			3	Pub-tap near UCO Bank dhalli	added	MPN=0	08-Jul-19	-	excellent
3396			4	Dhali tank	added	MPN=0	08-Jul-19	-	excellent
3397			5	Pub-tap yadgar	added	MPN=0	08-Jul-19	-	excellent
3398			6	Phase-3 tank	added	MPN=0	08-Jul-19	-	excellent
3399			7	Jakhu tank ropeway	added	MPN=0	08-Jul-19	-	excellent
3400			8	Persanal tap chauhan niwas adaresh niagar	added	MPN=0	08-Jul-19	-	excellent
3401			9	Pearsnal tap bittu general store khalini	added	MPN=0	08-Jul-19	-	excellent
3402			10	Pub-tap channel-9 khalini	added	MPN=0	08-Jul-19	-	excellent
3403			11	Pub-tap by pass road khalini	added	MPN=0	08-Jul-19	-	excellent
3404			12	Pub-tap panchiyeta	added	MPN=0	08-Jul-19	-	excellent