

Lab Sr. no.	Date	Received through Email/Phone No	Daily Sr No.	Source	Sodium Thiosulphate	MPN	Final report (72Hrs)	FINAL REPORTING DATE	Result
3769	27/7/19	Samples received from Assistant Engineer, Shimla Jal Prbandhan Nigam	1	KASUMPATI RESERVOIR	added	MPN=1	thermotolerant E.coli not detected	30/07/2019	satisfactory
3770			2	Supplies near banta bhawan Thakur bagh	added	MPN=0	thermotolerant E.coli not detected	30/07/2019	excellent
3771			3	Public tap near Shanti Kunj Annadel	added	MPN=0	thermotolerant E.coli not detected	30/07/2019	excellent
3772			4	Public tap near dhobighat Annadel	added	MPN=2	thermotolerant E.coli not detected	30/07/2019	satisfactory
3773			5	Public tap nearLamberdar niwas Annadel	added	MPN=0	thermotolerant E.coli not detected	30/07/2019	excellent
3774			6	Public tap near Krishna hill Annadel	added	MPN=1	thermotolerant E.coli not detected	30/07/2019	satisfactory
3775			7	Tara hall tank	added	MPN=3	thermotolerant E.coli not detected	30/07/2019	satisfactory
3776			8	SANJAULI RESERVOIR	added	MPN=2	thermotolerant E.coli not detected	30/07/2019	satisfactory
3777	27-07-19	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	Ridge tank	added	MPN=40		29-07-19	Unsatisfactory
3778			2	Mainsfield tank	added	MPN=50		29-07-19	Unsatisfactory
3779			3	Pub-tap Sanjauli chowk	added	MPN=10		29-07-19	
3780			4	Pub-tap old police station sanjauli	added	MPN=6		29-07-19	
3781			5	Pub-tap dhanda	added	MPN=180+		29-07-19	Unsatisfactory
3782			6	Knollswood tank	added	MPN=5		29-07-19	
3783			7	Pub-tap laxmi narayan tample Sanjauli	added	MPN=18		29-07-19	unsatisfactory
3784			8	Vikasnagar Tank	added	MPN=1		29-07-19	
3785			9	Pub-tap channel-9 khalini	added	MPN=180+		29-07-19	unsatisfactory
3786			10	Pub-tap Panchi hatta khalini	added	MPN=12		29-07-19	unsatisfactory

3787			11	Pub-tap guleria house khalini	added	MPN=1		29-07-19	
3788			12	Pub-tap brock host-1	added	MPN=2		29-07-19	
3789	28-Jul-19	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam	1	KASUMPATI RESERVOIR	added	MPN=0	thermotolerant E.coli not detected	31-Jul-19	excellent
3790			2	BANGALA COLONY TANK SANJUALI	added	MPN=0	thermotolerant E.coli not detected	31-Jul-19	excellent
3791			3	P.TAP NEAR BANGALA COLONY	added	MPN=0	thermotolerant E.coli not detected	31-Jul-19	excellent
3792			4	P.TAP NEAR MEHTA PARKING SANJUALI	added	MPN=0	thermotolerant E.coli not detected	31-Jul-19	excellent
3793			5	ENGINE GHAR TANK SANJUALI	added	MPN=0	thermotolerant E.coli not detected	31-Jul-19	excellent
3794			6	DHALLI TANK	added	MPN=0	thermotolerant E.coli not detected	31-Jul-19	excellent
3795			7	SANJUALI RESERVOIR	added	MPN=0	thermotolerant E.coli not detected	31-Jul-19	excellent
3796			8	P.TAP NEAR LAXMI NARAYAN MANDIR	added	MPN=0	thermotolerant E.coli not detected	31-Jul-19	excellent