

Lab Sr. no.	Date	Received through Email/Phone No	Daily Sr No.	Source	Sodium Thiosulphate	MPN	Final report (72Hrs)	FINAL REPORTING DATE	Result
4809	24/9/19	Samples received from Assistant Engineer, Shimla Jal Prabandhan Nigam Ltd	1	Kasumpati reservoir	added	MPN=0	thermotolerant E.coli not detected	27/09/2019	Excellent
4810			2	Advance study tank Summer hill(repeat)	added	MPN=1	thermotolerant E.coli not detected	27/09/2019	SATISFACTORY
4811			3	public tap near Summer hill chowk(repeat)	added	MPN=0	thermotolerant E.coli not detected	27/09/2019	Excellent
4812			4	public tap near Raj dairy Summer hill(repeat)	added	MPN=1	thermotolerant E.coli not detected	27/09/2019	SATISFACTORY
4813			5	Summer hill Bazar tank (repeat)	added	MPN=0	thermotolerant E.coli not detected	27/09/2019	Excellent
4814			6	public tap near lower summer hill(repeat)	added	MPN=0	thermotolerant E.coli not detected	27/09/2019	Excellent
4815			7	public tap near Totu chowk (repeat)	added	MPN=0	thermotolerant E.coli not detected	27/09/2019	Excellent
4816			8	Sanjauli reservoir	added	MPN=0	thermotolerant E.coli not detected	27/09/2019	Excellent
4817	24/9/19	Samples Received under Hepatitis Project Community Medicine IGMC Shimla	1	Ridge tank	added	MPN=1		26/9/19	
4818			2	mains field tank	added	MPN=1		26/9/19	
4819			3	Kelaston tank	added	MPN=0		26/9/19	Excellent
4820			4	Dhalli tank	added	MPN=3		26/9/19	
4821			5	Pub-tap dhanda	added	MPN=6		26/9/19	
4822			6	Knollswood tank	added	MPN=0		26/9/19	excellent
4823			7	Jakhoo tank ropeway	added	MPN=0		26/9/19	excellent
4824			8	Pub-tap near Apna Medical store Chotta Shimla	added	MPN=3		26/9/19	
4825			9	Pub-tap Police gumti Chotta Shimla	added	MPN=0		26/9/19	excellent
4826			10	Pub-tap apna medical store chotta Shimla	added	MPN=1		26/9/19	
4827			11	Pub-tap servent quarter chotta shimla	added	MPN=1		26/9/19	
4828			12	Pub-tap brock host	added	MPN=0		26/9/19	excellent