

**RESULTS OF BACTERIOLOGICAL SAMPLES RECEIVED ON DATED 08-10-2020**

Sr. No.	Collection Date	Lab. Code	Location of Sample taken	ANALYSIS RESULTS		Final Reporting Date
				Total Coliform MPN/100 ml	E.Coli MPN/100 ml	
1	08.10.2020	281	Kasumpati Reservoir	<1.1	Not Required	11.10.2020
2		282	Phase III Tank No 1	<1.1	Not Required	11.10.2020
3		283	Mainsfield Tank	<1.1	Not Required	11.10.2020
4		284	P. Tap Near Eva sale Corp. Ganj Bazar	<1.1	Not Required	11.10.2020
5		285	P. Tap near Suji line	<1.1	Not Required	11.10.2020
6		286	P. Tap near Purushartha Basti	<1.1	Not Required	11.10.2020
7		287	P.Tap near Sabji Mandi, Lower Bazar	1.1	<1.1	11.10.2020
8		288	P. Tap near Indera Chowk	1.1	<1.1	11.10.2020
9		289	Phagli Tank	23	<1.1	11.10.2020
10		290	P. Tap near GSSS Phagli	12	<1.1	11.10.2020
11		291	Supply near Nabha Guest House	<1.1	Not Required	11.10.2020
12		292	P. Tap near Tibtean Colony, Nabha	5.1	<1.1	11.10.2020
13		293	Chakkar tank	<1.1	Not Required	11.10.2020
14		294	P. Tap near Hari Palace, Ghora Chowki	<1.1	Not Required	11.10.2020
15		295	Sanjauli Reservoir	1.1	<1.1	11.10.2020
16		296	Giri Inlet	16	<1.1	11.10.2020
17		297	Gumma Inlet	<1.1	Not Required	11.10.2020
18		298	P.Tap near Sanjouli Chowk	3.6	<1.1	11.10.2020
19		299	P. Tap near Old Police Thana Sanjoli	<1.1	Not Required	11.10.2020
20		300	Dhalli Tank Outlet	<1.1	Not Required	11.10.2020